

Toledo Bend Reservoir - Water Releases

TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932

409/565-2273

FAX 409/565-2338

March 13, 2010

ADVISORY #5

Persons having interests in the Sabine River Basin below the reservoir are hereby advised that at 3:15 P.M. on Saturday, March 13, 2010, the reservoir elevation was 172.35' m.s.l. Currently, both generators are operating 24 hours per day, 7 days per week. **All spillway gates are closed.**

Interested persons should monitor current river and reservoir levels and reservoir release amounts since the river could reach flood stage and evacuation of persons, animals and property may become necessary.

Releases through the spillway gates, depending on upstream and downstream conditions, are made in accordance with the Guide for Spillway Gate Operation for Toledo Bend Reservoir dated March 1994, as Revised June 27, 2001. The first step is to open five gates one foot each.

The local sheriff's offices, as well as the Toledo Bend Project offices at the dam will be able to give the latest reported river stages and river forecasts from the National Weather Service, River Forecast Center.

Up-to-date reservoir elevations and releases may be obtained from the Toledo Bend Project offices on a 24 hour per day basis at 337/286-5253 and 409/565-2273.

Toledo Bend Reservoir is not a flood control reservoir and can experience significant rises in elevation in a short time span, as much as one to two feet in a 24 to 36 hour period.

Information on specific river gages can be obtained from the National Weather Service at the following web site:

<http://www.srh.noaa.gov/wgrfc>

Also, from the USGS at the following website: <http://tx.waterdata.usgs.gov>