TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 409/565-2273

59839 Hwy 191, Anacoco, LA 71403 337/286-5244 (Office) 337/286-5253 (Message)

ADVISORY #17

DATE: Tuesday, June 15, 2021

TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: 16:00 hrs

RESERVOIR ELEV: <u>172.27</u> FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM 11,000 cfs TO 5,000 cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES

Number of Gates	Opened (Feet)
5	01
XX	XX

GENERATORS

Generator #	Current Status
1	24 hrs at 7,766 cfs
2	24 hrs at 6,341 cfs

TOTAL RELEASES

	(CFS)
SPILLWAY	5,000
GENERATORS	14,107
TOTAL	19,107

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com, www.sratx.org and from the National Weather Service at the following websites: http://www.weather.gov/wgrfc and from the USGS at the following websites: https://tx.waterdata.usgs.gov or https://la.waterdata.usgs.gov.