TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 409/565-2273

59839 Hwy 191, Anacoco, LA 71403 337/286-5244 (Office) 337/286-5253 (Message)

ADVISORY #3

DATE: Monday May 10, 2021

TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: 03:15 hrs

RESERVOIR ELEV: <u>172.53</u> FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM 300 cfs TO 5000 cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES

Number of Gates	Opened (Feet)
5	01
XX	XX

GENERATORS

Generator #	Current Status
1	24 hrs at 7900 cfs
2	24 hrs at 6500 cfs

TOTAL RELEASES

	(CFS)
SPILLWAY	5000
GENERATORS	14400
TOTAL	19400

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com, www.sratx.org and from the National Weather Service at the following websites: http://www.weather.gov/wgrfc and from the USGS at the following websites: https://tx.waterdata.usgs.gov or https://la.waterdata.usgs.gov.