

TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 59839 Hwy 191, Anacoco, LA 71403
409/565-2273 337/286-5244 (Office)
337/286-5253 (Message)

ADVISORY # 5

DATE: Thursday, May 6, 2021

TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: 1730 hrs

RESERVOIR ELEV: 172.24 FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM 11,000 cfs TO 5,000 cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES

Number of Gates	Opened (Feet)
05	01
XX	XX

GENERATORS

Generator #	Current Status
1	24 hrs at 7,900 cfs
2	24 hrs at 6,500 cfs

TOTAL RELEASES

	(CFS)
SPILLWAY	5,000
GENERATORS	14,400
TOTAL	19,400

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com, www.sratx.org and www.setexasrain.org. Information on specific river gauges can be obtained from the National Weather Service at the following website: <http://www.weather.gov/wgrfc> and from the USGS at the following websites: <http://tx.waterdata.usgs.gov> or <https://la.waterdata.usgs.gov>.

Actual flood conditions may vary significantly from the alert based on new or changed conditions; advanced alerts of changed conditions may not be possible. <TX Leg. HB26