TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 409/565-2273

59839 Hwy 191, Anacoco, LA 71403 337/286-5244 (Office) 337/286-5253 (Message)

ADVISORY #4

DATE: Tuesday May 4, 2021

TOLEDO BEND RESERVOIR - WATER RELEASES

AS OF TIME: <u>23:15 hrs</u>

RESERVOIR ELEV: <u>172.74</u> FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM 5000 cfs TO 11000 cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES

Number of Gates	Opened (Feet)
11	01
XX	XX

GENERATORS

Generator #	Current Status
1	24 hrs at 7740 cfs
2	24 hrs at 6330 cfs

TOTAL RELEASES

	(CFS)
SPILLWAY	11000
GENERATORS	14070
TOTAL	25070

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com, www.sratx.org and from the National Weather Service at the following websites: http://www.weather.gov/wgrfc and from the USGS at the following websites: https://tx.waterdata.usgs.gov or https://la.waterdata.usgs.gov.