

TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 59839 Hwy 191, Anacoco, LA 71403
409/565-2273 337/286-5244 (Office)
337/286-5253 (Message)

ADVISORY # 12

DATE: Thursday, May 7, 2020

EVENT OVER-OPERATIONS BACK TO NORMAL TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: **0530hrs**

RESERVOIR ELEV: **171.82** FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM **5000** cfs TO **300** cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES – ALL GATES CLOSED

Number of Gates	Opened (Feet)
0	0

GENERATORS

Generator #	Current Status
1	24 hrs @ 7650
2	24 hrs @ 6285

TOTAL RELEASES

	(CFS)
SPILLWAY	300
GENERATORS	13935
TOTAL	14235

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com , www.sratx.org and www.setexasrain.org. Information on specific river gauges can be obtained from the National Weather Service at the following website: <http://www.weather.gov/wgrfc> and from the USGS at the following website: <http://tx.waterdata.usgs.gov>.