TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 409/565-2273

59839 Hwy 191, Anacoco, LA 71403 337/286-5244 (Office) 337/286-5253 (Message)

ADVISORY # 10

DATE: Friday, April 26, 2024
EVENT OVER-OPERATIONS BACK TO NORMAL
TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: 1330 hrs

RESERVOIR ELEV: 171.90 FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM 5000 cfs TO 300 cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES - ALL GATES CLOSED

Number of Gates	Opened (Feet)
1	0.3

GENERATORS

Generator #	Current Status
1	24 hrs @ 7429 cfs
2	24 hrs @ 5846 cfs

TOTAL RELEASES

	(CFS)
SPILLWAY	300
GENERATORS	13275
TOTAL	13575

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com, www.sratx.org and from the National Weather Service at the following website: http://www.weather.gov/wgrfc and from the USGS at the following website: http://tx.waterdata.usgs.gov.

Actual flood conditions may vary significantly from the alert based on new or changed conditions; advanced alerts of changed conditions may not be possible.