TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 409/565-2273

59839 Hwy 191, Anacoco, LA 71403 337/286-5244 (Office) 337/286-5253 (Message)

ADVISORY #5

DATE: Saturday, April 13, 2024

TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: 2030 hrs

RESERVOIR ELEV: <u>172.90</u> FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM 11000 cfs TO 22000 cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES

Number of Gates	Opened (Feet)
11	02

GENERATORS

Generator #	Current Status
1	24 hrs at 7384 cfs
2	24 hrs at 5849 cfs

TOTAL RELEASES

	(CFS)
SPILLWAY	22000
GENERATORS	13233
TOTAL	35233

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com, www.sratx.org and from the National Weather Service at the following websites: http://www.weather.gov/wgrfc and from the USGS at the following websites: https://tx.waterdata.usgs.gov or https://la.waterdata.usgs.gov.

Actual flooding conditions may vary significantly from the alert based on new or changed conditions; advanced alerts of changed conditions may not be possible.